



LABOR RELATIONS DIVISION

401 Broadway NE
Albuquerque, NM 87102
Phone: 505-841-4400
Fax: 505-841-4424

226 South Alameda Blvd
Las Cruces, NM 88005
Phone: 575-524-6195
Fax: 575-524-6194

WWW.DWS.STATE.NM.US

Wage Decision Approval Summary

1) Project Title: Domestic/Fire water line replacement
Requested Date: 08/08/2024
Approved Date: 08/09/2024
Approved Wage Decision Number: SF-24-2568-B

Wage Decision Expiration Date: 12/07/2024

2) Physical Location of Jobsite for Project:
Job Site Address: 424 Galisteo
Job Site City: Santa Fe
Job Site County: Santa Fe

3) Contracting Agency Name (Department or Bureau): State of New Mexico General Services Department
Contracting Agency Contact's Name: Joaquin Nielsen
Contracting Agency Contact's Phone: (505) 470-8496 Ext.

4) Estimated Contract Award Date: 07/30/2024

5) Estimated total project cost: \$1,370,238.63
a. Are any federal funds involved?: No
b. Does this project involve a building?: Yes - Interior water lines in the mechanical room will be replaced to provide independent water lines for domestic and fire suppression systems to be in current code requirements for commercial buildings. In addition it will allow for the domestic water shut off for repairs without shutting down the Fire suppression system
c. Is this part of a larger plan for construction on or appurtenant to the property that is subject to this project?: No
d. Are there any other Public Works Wage Decisions related to this project?: No
e. What is the ultimate purpose or functional use of the construction once it is completed?: To provide separate water shut offs and pressure relief points for the domestic and fire water systems

6) Classifications of Construction:

Classification Type and Cost Total	Description
General Building (B) Cost: \$1,370,238.63	Interior water lines in the mechanical room will be replaced to provide independent water lines for domestic and fire suppression systems to be in current code requirements for commercial buildings. In addition it will allow for the domestic water shut off for repairs without shutting down the Fire suppression system