



**LABOR RELATIONS DIVISION**

401 Broadway NE  
Albuquerque, NM 87102  
Phone: 505-841-4400  
Fax: 505-841-4424

226 South Alameda Blvd  
Las Cruces, NM 88005  
Phone: 575-524-6195  
Fax: 575-524-6194

**WWW.DWS.STATE.NM.US**

**Wage Decision Approval Summary**

1) Project Title: Clovis Regional Airport Fuel Farm Rehab & Upgrade  
Requested Date: 05/07/2024  
Approved Date: 05/08/2024  
Approved Wage Decision Number: CU-24-1626-A

**Wage Decision Expiration Date for Bids: 09/05/2024**

2) Physical Location of Jobsite for Project:  
Job Site Address: 459 CR 11.5  
Job Site City: Texico  
Job Site County: Curry

3) Contracting Agency Name (Department or Bureau): City of Clovis  
Contracting Agency Contact's Name: Amanda Cook  
Contracting Agency Contact's Phone: (575) 763-9634 Ext.

4) Estimated Bid Opening Date: 06/04/2024

5) Estimated total project cost: \$180,000.00  
a. Are any federal funds involved?: No  
b. Does this project involve a building?: No  
c. Is this part of a larger plan for construction on or appurtenant to the property that is subject to this project?: No  
d. Are there any other Public Works Wage Decisions related to this project?: No  
e. What is the ultimate purpose or functional use of the construction once it is completed?:  
The contractor will install a pumping system for both Jet fuel and AVgas systems to allow fuel delivery from the truck into the tanks through the filtration system.  
Upgrade existing 2" fuel pipes to 3" (both AVgas and Jet)

6) Classifications of Construction:

Classification Type and Cost Total	Description
<b>Highway/Utilities (A)</b> <b>Cost: \$180,000.00</b>	The contractor will install a pumping system for both Jet fuel and AVgas systems to allow fuel delivery from the truck into the tanks through the filtration system. Contractor shall construct and install the replacement of the current existing 2-(two inch) fuel pipe and upgrade to a 3-(three inch) The Contractor will install pumps into the existing system to allow fuel delivery, the current system is gravity-fed. The new piping and pumps will be connected to the existing fuel storage tanks currently located at the airport. The existing submersible pumps, anti-siphon valves, and floating suction arms will remain in place and be used for dispensing. Electrical power and communications to the new facility will be provided. The piping and pump fueling infrastructure will be based on the Engineers standards complying with the International Fire Code,

	<p>NFPA 407, NFPA 30, NEC, and state and local municipal building and fire codes. The City of Clovis has adopted the 2015 edition of the International Fire Code. All construction and renovations shall comply with this code.</p>
--	---